

## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE


No. 755

Dated: 21.07.2025

It is certified that an inspection team headed by Mr. Jasdeep Singh (Name of Officers with designation) from Water Supply & Sanitation Department PHED Inspected The British School, Patti, Distt. Tarn Taran (Name & Address of the school) on 21.07.2025(date of inspection) and on the basis of Water Test Report (Attached) bearing no.DWTLTT/2526/00151 dated 17.07.2025 of (PHED Lab) certified that The British School, Patti, Distt. Tarn Taran ( Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 21.07.2026.

  
Sub Divisional Engineer  
Water Supply & Sanitation Sub Division  
Patti

Signature with Seal: .....  
Name: Sub Division Engineer  
Designation: Water Supply & Sanitation Department  
Name & Address of the Office / Department:  
Sub Division Patti

To  
THE BRITISH SCHOOL  
PATTI, DISTT. TARN TARAN  
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

# DISTRICT WATER TESTING LABORATORY, TARN TARAN

Village Kakka Kandiala, Block -Tarn Taran District -Tarn Taran.

dwtl1@gmail.com



TC-14756

## TEST REPORT

Name & Address of Customer : <b>The British School Patti , Tarn taran</b>		Customer Reference No.	<b>No : 527 Dated : 16/07/2025</b>
		Sample Submitted by	<b>Mr. Sukhraj Singh</b>
		Date of Sample Receipt	<b>16/07/2025</b>
		Analysis Starting Date	<b>16/07/2025</b>
		Analysis completion Date	<b>17/07/2025</b>
Discipline : <b>Chemical Testing</b>		Group: <b>Water</b>	
ULR No.:	<b>TC14756250000250F</b>	Sample Type :	<b>Water</b>
Test Report No.:	<b>DWTLTT/2526/00151</b>	Date of Issue :	<b>17/07/2025</b>
Registration no.:	<b>DWTLTT/REG2526/00561</b>	Condition of Sample :	<b>Unsealed</b>
Collection Point:	<b>Private Submersible</b>	Quantity/Type of Bottle:	<b>2000 ml / Plastic Bottles</b>
Scheme/Source:	<b>Not Mentioned(Not Mentioned)</b>	Location/Depth :	<b>NA / NA</b>
Village :	<b>Not Mentioned</b>	Habitation :	<b>Not Mentioned</b>
Block:	<b>Not Mentioned</b>	District :	<b>Tarn Taran</b>
Latitude :	<b>Not Mentioned</b>	Longitude:	<b>Not Mentioned</b>

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	8.04@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	2	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	182	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL@25°C	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO3)	180	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO3)	124	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	19.24	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	18.47	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	13.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. \* Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

**Mr. Mohammad Naushad Alam**  
Quality Manager  
Authorized Signatory  
For, District Water Testing Laboratory  
Tarn Taran

----- End of the Test Report -----

**DISTRICT WATER TESTING LABORATORY, TARN TARAN**

Village Kakka Kandiala, Block -Tarn Taran District -Tarn Taran.  
dwtl1@gmail.com

To,

The British School  
Patti , Tarn taran


No.: DWTLTT/2526/00151 Dated : 17/07/2025

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 527 Dated: 16/07/2025

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 16/07/2025. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Tarn Taran

D/A : Test Report



**Authorized Signatory  
For, District Water Testing Laboratory  
Tarn Taran**